

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/Metro/2024/SZ/ 132  
To

Dated: 19/03/2024

The Chief General Manager/V& Y  
Delhi Metro Rail Corporation,  
Metro Bhawan, Fire Brigade Lane,  
New Delhi 110001

Sub: - Regarding issuance of FSC in r/o M/s R.K Puram Underground Metro Station  
(Line-8) New Delhi

Sir,

This has reference to your letter no DMRC/O&M/Fire/NOC/L-8/2023/12/04 Dated 26/12/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 14.03.2024 in the presence of Mr. Bhirgu Fukan (AM/Fire) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Some of the hose cabinet found damaged and need to be repaired / replaced.
2. Some of the electrical shaft not found properly sealed.
3. LV Electrical panels are not provided with clear agent flooding system.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

*[Handwritten signature]*