

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/Metro/2024/SZ/ 141

Dated: 20/03/2024

To

The Chief General Manager/V& Y
Delhi Metro Rail Corporation,
Metro Bhawan, Fire Brigade Lane,
New Delhi 110001

Sub: - Regarding issuance of FSC in r/o M/s Vasant Vihar Underground Metro Station
(Line-8) New Delhi

Sir,

This has reference to your letter no DMRC/O&M/Fire/NOC/L-8/2023/12/02
Dated 26/12/2023 on the subject cited above. In this connection, this is to inform you
that the above mentioned premise was visited by the officer concerned of this
department on 14.03.2024 in the presence of Mr. Bhirgu Fukan (AM/Fire) to verify the
fire safety measures installed in the building. Accordingly fire safety arrangement were
tested / checked and found following observation.

1. Some of the hose cabinet found damaged and need to be repaired /
replaced.
2. Some of the electrical shaft not found properly sealed.
3. LV Electrical panels are not provided with clear agent flooding system.

In view of above Shortcomings, the application for issuance Fire Safety
Certificate is rejected. The occupancy of the building/premises in absence of requisite
fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE