



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/102
आफ़ादीक
अमृत मयोलस्य

No. F6/DFS/MS/GH/SZ/2024/06

Dated: 20/03/2024

To

The Joint Commissioner of Police,
Office of Joint Commissioner of Police: Licensing,
1st Floor, P. S Defence Colony, New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Central Guest House, Bldg no. -4 & 5, Mahila Park Road, Basti Hazrat Nizamuddin (West), New Delhi- 13.

Sir,

With reference to the MHA online application no. 2024022602162 dated 26.02.2024 on the subject cited above, it is informed that the said building was inspected by officer concerned of this department on 06.03.2024 in the presence of manager and it was observed that following shortcomings were observed:

1. No alternate exit is available to the occupants of building no. 5. Same may be arranged by linking both the building at all floor levels.
2. Alternate exit of building no. 4 shall not be occupied by shops/combustibles.
3. The main staircase of both the buildings are not linked to terrace same shall be arranged.
4. Room on terrace shall be removed/demolished.
5. Hose reel/downcomer system at 1st floor shall be placed inside the building. Its present location is inaccessible.
6. Ventilation arrangements in the common areas shall be made in building no. 5.
7. Electrical meters & panels shall be relocated away from the staircase.
8. Entry/exits to the building shall be made free from parking.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

07/03/24