

C/06

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2024/ EH | III

Dated:- 20/03/2024

To

The Manager,
M/S GOKULAM,
86, Ground floor, Janpath,
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S GOKULAM, 86, Ground floor, Janpath, New Delhi.

Sir,

This has reference to online ID No. 2024022902358 dated 01.03.24, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 13/03/2024 in the presence of Mr. Chandra Sekher, (Manager) and following shortcomings were observed:-

1. 02 exits of 1.5 meter each are required against the provision of 02 exits of 1.25 & 1.35 meter.
2. First aid hose reel, hydrant systems & MOEFA are not provided.
3. Terrace pump of 450 LPM is not provided.
4. Overhead fire water tank of 20,000 liter capacity is not provided.

In view of above, the case is rejected with a request to rectify the shortcomings for further consideration in the matter.

Yours faithfully

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.