

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

c/66

NO. F6/DFS/MS/SZ/2024/107

DATED: 20/3/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

**Subject: - Renewal of Fire safety Certificate in r/o M/s Grand President Guest House
Located at 17A/8, WEA, Karol Bagh, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024012900954, dated 29/02/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 13/03/2024 in the presence of Sh. Mukesh Yadav (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Smoke exhaust system at upper floors found inadequate/ not provided.
2. CO detectors found not provided.
3. Terrace pump found nonfunctional on auto mode.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,

(Atul Garg)
Director,
Delhi Fire Service.

ek

Copy to:-

1. The Manager, M/s Grand President Guest House Located at 17A/8, WEA, Karol Bagh, New Delhi - 110005.