

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2024/ 144

Dated: 20/03/2024

To,

The Authorized Signatory,
Plot No. 10 A, Shivaji Marg,
Moti Nagar, New Delhi- 110015.

Subject: **Regarding issuance of fire safety certificate in r/o Plot No. 10 A, Shivaji Marg, Moti Nagar, New Delhi-110015.**

Sir,

Please refer to your letter dated 04/03/2024, received through outdoor diary no. 13878 dated 05/03/2024 on the subject cited above. In this connection, it is to inform you that the premises/Building was inspected by the officers concerned by this department on 12/03/2024 in the presence of Sh. Rajiv Bhatia to check the shortcomings already issued vide letter no. F6/DFS/MS/91 dated 15/01/2024.

The Status of the Shortcoming is as under:-

S. no.	Shortcomings	Status
1.	Fire check doors are not provided.	Not Rectified
2.	Smoke management system is not provided.	Provided but not functional
3.	First-Aid Hose Reel is provided but not functional.	Rectified
4.	Automatic fire detection and alarming system is not provided.	Provided but not functional
5.	MOEFA is provided but not functional.	Provided but not functional
6.	Automatic sprinkler system is provided but not functional.	Rectified
7.	Ground Level Pump 2280 LPM, Jockey Pump 180 LPM is provided but not functional & electric pump is provided instead of stand by diesel pump.	Not Rectified
8.	Terrace level pump 900 LPM is provided but not functional.	Rectified
9.	Underground tank capacity of 2,00,000ltr found empty & overhead tank capacity of 50,000ltr is not provided.	Overhead tank not provided
10.	Lift fireman's grounding switch is provided but not functional. Lift signages is not provided.	Rectified

In view of above, application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,

(Atul Garg)
Director

Copy To: -

1. The Executive Engineer (Building), MCD, Karol Bagh Zone, Anand Parbat, New Delhi.
(Email Id: - eepwddelhim132@gmail.com)