

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F.6/DFS/MS/ BP/2024/ 143

Dated: 20/03/2024

To,

The Executive Engineer (Bldg.) HQ,
Municipal Corporation of Delhi,
Dr. S.P.M Civic Centre, JLN Marg
Delhi-110002.

Sub: Clearance from fire safety point of view in r/o Plot No. 47, Block No. 1, W.H.S
Kirti Nagar, New Delhi.

Sir,

Please refer your ID No. 10118319 dated 14/03/2024 on the above cited subject. In this connection, this is to inform you that the online building plans in respect of proposed building have been scrutinized by this department from fire safety point of view. The details are as under: -

Following shortcomings are observed:

1. 6m wide road all around the building is not proposed as per clause 8.2 of UBBL-2016.
2. Fire Safety arrangement is not proposed for as mentioned in the plan i.e storage occupancy, as per NBC part 4,2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


(Atul Garg)
Director
011-23414000

w c 15