



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6 /DFS/MS/C.C/NDZ/2024/47

Dated: 15/03/2024

To,

The Manager
Vidyapeeth (Physics Wala)
Building No. 06, New Rajdhani Enclave,
Delhi – 110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o M/s Vidyapeeth (Physics Wala) located at Building No. 06, New Rajdhani Enclave, Delhi – 110092.

Sir,

This has a reference to your Outdoor Diary No. 12617 dated 02.02.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 29/02/2024 in the presence of Mr. Devender Singh Yadav (Manager) and observed that building comprised of basement plus Ground plus three upper floors only.

Following shortcomings were observed during time of inspection:

1. Two staircase of width 1.50 meter & 1.20 meter are provided against requirements of 1.50 meter each.
2. First-Aid-Hose Reel not functionable.
3. MOEFA not functionable.
4. Internal Hydrant not functionable.
5. Fire pump not functionable.
6. Overhead tank of 10,000 liters capacity is provided against the requirement of 15,000 liters
7. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

O/C DELHI FIRE SERVICE

Copy to: -

1. The Manager, Vidyapeeth (Physics Wala) located at Building No. 06, New Rajdhani Enclave, Delhi – 110092.