

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/ 147
To

Dated: 21/03/2024

Mr. Rajneesh Bhatnagar,
CFM (Civil) Building Administrator,
Deendayal Urja Bhawan, ONGC,
Plot No. 5A & 5B Nelson Mandela Marg,
Vasant Kunj, New Delhi-110070.

Sub: Regarding grant of Fire Safety Certificate (FSC) in r/o Deendayal Urja Bhawan, ONGC, Plot No. 5A & 5B Nelson Mandela Marg, Vasant Kunj, New Delhi-110070.

Sir,

This has reference to your letter received through Outdoor diary No 11860 dated 12/01/2024 on the subject cited above. In this connection, it is inform you that the premise was inspected by the officers concerned of this department on 17/03/2024 in presence of Mr. Rajesh Kumar Sharma (Fire Officer) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation

1. The Self Closing devices of Fire Check Door are found defective at some places.
2. The corridor pathway at some places found encroached with wooden fixtures, which needs to be clear.
3. Smoke management systems are not on auto mode. Smoke exhaust & fresh air fan found in the same enclosure. Hence there is a short circuit of fresh air and exhaust system.
4. Pressurization of lift lobbies is found not functional.
5. The Exit Signage's found removed at some places.
6. Wooden Materials / items shall have to be fire resistant paint and certificate in this concerned shall also be provided.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer. (Bldg.), MCD, Green Park, Aurobindo Marg, Delhi-110016