

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2024/SZ/ 153
To

Dated: 22/03/2024

The Authorized Signatory,
M/s Mansarovar Building,
Plot No 90, Nehru Place, New Delhi 110019

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Mansarovar Building located at Plot No 90, Nehru Place, New Delhi 110019

Sir,

This has reference with letter received through outdoor diary no 13940 dated 06/03/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 20/03/2024 in the presence of Mr. Sanjay Kumar and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check doors & self closing device found removed at some place.
2. Smoke ventilation system provided but found nonfunctional.
3. First aid hose reel provided but found not functional.
4. Automatic detection system not provided in some of the cabins / compartments.
5. Sprinkler System provided but found not functional.
6. Fire fighting pumps are not on auto mode.
7. Electrical installation / meter found installed in the escape routes near staircases, which is not acceptable.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

