

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2024/SZ/ 152
To,

Dated: 22/03/2024

The Authorized Signatory,
Meghdoot Building, Plot No.94,
Nehru Place, New Delhi-110019

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Meghdoot Building, Plot No.94, Nehru Place, New Delhi-110019.

Sir,

This is in reference with your letter received through outdoor diary no.13939 dated 16/03/2024, on the subject cited above. It is to inform you that the premise was inspected by the concern nominated authority of this department in presence of Mr. Ashok Arora on 20/03/2024 to verify the compliance of fire prevention and fire safety measures required under the rules. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Some of the Fire Check Doors found damaged and Fire Check Doors are not self-closing.
2. Sealing of shafts found removed.
3. Automatic fire detection system found removed from the building.
4. Public Address System found removed from basement.
5. Heads of Automatic Sprinkler system found removed from some of the places.
6. 1620 LPM & 39m head terrace pump found replaced with 900 LPM pump.
7. The 25,000 Liter captive water storage at terrace is not dedicated for firefighting.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Executive Engineer (Bldg.), SDMC, Jal Vihar, Lajpat Nagar, New Delhi-110024