

c/68

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/ GH | 112

DATED: 29/03/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/s Delhi Pride Guest House Located at 12A/28, Saraswati Marg, New Delhi - 110005.

Sir,

Please refer to online application No. 2024022702244, dated 07/03/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 14/03/2024 in the presence of Sh. Manjeet Singh from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Smoke exhaust fans provided in basement not interlinked with MOEFA.
2. Exhaust fans provided in atrium found nonfunctional and not interlinked with MOEFA.
3. CO detectors found nonfunctional.
4. Terrace pump found nonfunctional on auto mode.
5. Communication system found not ^{non functional} provided in lift car.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Manager, M/s Delhi Pride Guest House Located at 12A/28, Saraswati Marg, New Delhi - 110005.