

c/53



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आजादी
अमृत महोत्सव

No. F6/DFS/MS/WZ/2024/ Schol/131

Dated:- 22/03/2024

To,

The HOS,
Govt. Girls Sr. Sec. School (ID-1617021),
Nangloi, Delhi-110041.

Subj.:- Regarding renewal of Fire Safety Certificate in respect of Govt. Girls Sr. Sec. School (ID-1617021), located at Nangloi, Delhi-110041.


Sir,

Please refer to your letter no. GGSSS/Nangloi/2024/389 dated 16/02/2024 on the subject cited above. In this connection, it is to inform you that the above said school building have been re-inspected by the officer concerned of this department on 13/03/2024 in the presence of Ms. Sunita Kumari Meena (HOS). During inspection, it has been observed that the school building is comprised of 02 blocks of Ground + 01 upper floor, 01 block of ground floor & 01 block of Ground + 03 Upper Floors. However, the following shortcoming has been observed:-

1. Electrical meters/panels found under the staircases same shall be shifted on another safe place.

In view of the above shortcoming, the application for renewal of Fire safety Certificate cannot be considered at this stage & rejected. You are advised to rectify the above mentioned shortcoming under intimation to this department for taking further necessary action.

Yours faithfully,


(Atul Garg)
Director
8/9/3
22/03/24

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.