

c-45

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/SZ/2024/ 139

Dated: -27 .03.2024

To,

The Principal,
Bal Bharti Public School,
Pusa Road, New Delhi- 110005.

Sub.:- Regarding issuance of Fire Safety Certificate in r/o Bal Bharti Public School, Pusa Road, New Delhi- 110005.

Sir,

Please refer to your letter No. letter No. nil, dated 28.02.2024 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. Akhilesh Kashyap (Estate Officer) of the School on 20.03.2024 to check the fire safety arrangements recommended vide this office letter No. F6/DFS/MS/BP/2020/217, dated 29.06.2020 in the building. During the course of inspection, the following shortcomings were observed: -

1. Fire Pump house having one electric pump of 2280LPM capacity, one standby diesel pump of 2280LPM capacity having suitable head and one jockey pump of 180LPM not provided.
2. Under ground water storage tank of capacity 2,00,000 liters for fire fighting not provided.
3. Exit signs found removed at many places.

In view of the above, 'Fire Safety Certificate' cannot be issued at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully


(Anil Garg)
Director

Delhi Fire Service

Copy to: -

The Director of Education,
Govt. of NCT of Delhi,
Old Secretariat, Delhi