

c/36



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2024/School/ 148

Dated: 28 /03 /2024

To

Smt. Kavita Sharma (Admin),
 Burari Public School at 25 futa Road,
 Sunil Colony, Near Kaushik Enclave,
 Burari, Delhi-110084.

Sub: - Regarding issuance of fire safety certificate in r/o Burari Public School at 25 futa Road, Sunil Colony, Near Kaushik Enclave, Burari, Delhi-110084.

Sir,

Please refer to your letter no. Nil dated 05.03.2024 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 15.03.2024 to verify the fire safety measures issued vide NBC Pat-IV and observed that as per earlier shortcomings issued by this department letter of even no. F-6/DFS/HQ/2020/135 dated 25.02.2020 the building was comprised of ground + first floor only. Now the building is comprised of Ground & 02 upper floor only. At the time of inspection Smt. Kavita Sharma (Admin) was also present at site. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. There is 01 staircase of 02m provided ground to terrace level and 01 ramp width of 1.50m ground to first floor only against the requirement of one more staircase width of 1.50m from ground to terrace level.
2. The width of class room doors is 01m against the requirement of 1.20m
3. First aid hose reel hose is not provided.
4. MOEFA system is not provided.
5. Terrace level fire pump capacity of 450lpm is not provided.
6. Terrace level fire fighting water tank capacity of 10,000ltr is not provided.
7. Exit signage and floor signage not provided at strategic locations in the school building.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Signature)
 (Atul Garg)
 Director

Ph:-011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054. *(Signature)*