

c-15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/School/2024/ 137

Dated: 22/03/2024

To,

The Principal,
Divya Public School,
F-1/48, Budh Vihar,
Delhi-110086.

Sub: Issue of FSC in r/o Divya Public School, F-1/48, Budh Vihar, Delhi-110086.

Sir,

Kindly reference to online e-mail dated 25.01.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **08.03.2024**, in presence of **Smt. Indu Bala (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 06 fire extinguishers of ABC type provided but not functional.
2. Hose reel provided but not functional.
3. Terrace Fire pump with capacity of 450 LPM provided but not functional.
4. 4000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs.
5. Exit signage not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules
[/http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms)

Yours faithfully


(Atul Garg)
DIRECTOR
Ph; 011-23414000

su
24