

C-134

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/ 119

Dated: 26/03/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Duke Guest House located at 5043 - 44/8, Netaji Subhash Marg, Daryaganj, New Delhi.

Sir,

This has reference to online application I.D. no. 2024030902787 dated 14.03.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 21.03.2024 in the presence of Mr. H. S. Bhatia (Owner) and it was observed that building is comprised of Ground + mezzanine + 03 upper floors. During inspection, following shortcomings were observed:

1. CO detectors with panel and alarm which are required as per gazette notification dated 27.05.2019, not provided.
2. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service 011
Tel: 011-23414000

Copy to:-

The Licensee,

M/s Duke Guest House at 5043 - 44/8, Netaji Subhash Marg, Daryaganj, New Delhi.

w/ 21/3