



No. F6 /DFS/MS/School/NDZ/2024/ 149

Dated: 28/03/2024

To,

Mrs. Parvati Nautiyal (State Manager),
St. Eknath Govt. Sarvodaya Kanya Vidyalaya,
J & K Block, Dilshad Garden,
Delhi - 110095.

Sub: - Regarding grant of Fire Safety Certificate in r/o St. Eknath Govt. Sarvodaya Kanya Vidyalaya, located at J & K Block, Dilshad Garden, Delhi-110095.

Sir,

This has a reference to your email dated 13/03/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 05/01/2024 in the presence of Mrs. Parvati Nautiyal (State Manager) and observed that building comprised of ground plus three Upper floors. (New building, one block).

Following shortcomings were observed during time of inspection:

1. Fire extinguishers not provided.
2. First-Aid-Hose Reel provided but not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

01/03/24
DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B – Block, Yamuna Vihar, Delhi – 110053.