

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

Dated: 22/03/2024

No. F.6/DFS/MS/School/2024/SZ/ 130
To

The Principal,
Govt. Girls Senior Secondary School,
Harkesh Nager, New Delhi 110020

Sub: Reg. renewal of Fire Safety Certificate in r/o Govt. Girls Senior Secondary School,
Harkesh Nager, New Delhi (School ID 1925341)

Sir,

This is in reference with your Gmail dated 23/01/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.03.2024 in the presence of Ms. Sheetal (Principal) to verify the fire safety measures installed in the building. During the course of inspection, the shortcomings observed are as below;

1. Hose reel found non-functional in ground plus three blocks and not provided in ground plus two upper floor blocks.
2. Terrace pumps found non-functional in ground plus three blocks and not provided in ground plus two upper floor blocks.
3. Overhead tank capacity 10,000 ltrs not provided in ground plus two upper floor blocks.

The same observation has already been issued and communicated earlier by this department vide letter of even no 195 dated 07.04.2021 & letter of even no 432 dated 04/10/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat Delhi 110054