

cl/2

DRAFT



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2024/ 146

Dated: 28/03/2024

To

The Principal,
Hingiri Public School
B-1265/3, Sangam Vihar, New Delhi-62.

Sub:- Regarding renewal of Fire Safety Certificate in r/o M/s Hingiri Public School located at B-1265/3, Sangam Vihar, New Delhi-62.

Sir,

With reference to your email dated 09.10.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 19.03.2024 in the presence of Mr. Rajiv Katyal (Manager) and it was observed that the school building is comprised of Basement (sealed) + Ground + 01 upper floor. During the inspection following shortcomings were observed:-

1. Hose reel found non-functional.
2. Fire pump found removed.
3. Fire tank found removed.
4. Exit signages found removed.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Ajul Garg)

Director

Delhi Fire Service

28/3/24

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.