

CA

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/ 122

DATED: 26/03/2024

To,

The Joint Commissioner of Police (Lic),
1st Floor, Licensing Unit, Police Station,
Defence Colony, New Delhi

Subject: - Renewal of Fire safety Certificate in r/o M/s Hotel Sunstar Located at 7A/17, WEA, Karol Bagh, New Delhi - 110005.

Sir,

Please refer to online application No. 2023121919711, dated 01/03/2024 on the subject mentioned above. In this connection it is submitted that the above said premises was visited by the officer concerned of this department on 13/03/2024 in the presence of Sh. Deepak (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check doors found not provided.
2. Smoke exhaust system at upper floors found inadequate/ not provided.
3. CO detectors found not provided.
4. Terrace pump found nonfunctional on auto mode.
5. Lift running from basement to upper floors. The lift must be segregated/ protected by Fire Check Door.
6. Setup of eating house was seen in basement. Therefore need to be clarified.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. Applicant may be directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)

Director,

Delhi Fire Service

Copy to:-

1. The Manager, M/s Hotel Sunstar Located at 7A/17, WEA, Karol Bagh, New Delhi - 110005.