

c/6

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI**

No. F6/DFS/MS/SZ/2024/123

Dated: 27/13/2024

To,

The Addl. Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit, Police Station,  
Defence Colony, New Delhi.

**Subject: Issuance of NOC from fire safety point of view in r/o M/s Indra Restaurant Located at Plot No. 9A/33, Ground Floor, WEA Karol Bagh, New Delhi - 110005.**

Sir,

Please refer to online application No. 2024022902364, dated 03/06/2024 on the subject mentioned above. In this connection it is to inform you that the premise was inspected by the officers concerned from this department on 21/03/2024 in the presence of Sh. Shrikant Deshmukh from fire safety point of view.

During the course of inspection the following shortcomings are observed.

1. Two Exits of 1.5 M clear width found not provided.
2. Hydrant & Hose Reels are found not provided.
3. MOEFA found not provided.
4. Terrace pump of 450 LPM found not provided.
5. Terrace fire water tank of 20,000 ltrs capacity not provided.
6. Exit signage found not provided.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. Applicant may be directed to comply the shortcomings under intimation with this department for further consideration in the matter.

(Atul Garg)  
Director  
Delhi Fire Service

ok

22/3/24

Copy to: -

The Manager, M/s Indra Restaurant Located at Plot No. 9A/33, WEA Karol Bagh,  
New Delhi - 110005.