

C-182

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No. F6/DFS/MS/GH/NDZ/2024/120

Dated: 26/03/2024

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s New Royal Guest House situated at 1643, SPM Marg, Delhi - 110006.

Sir,

This has reference to online application I.D. no. 2024020701315 dated 08.03.2024 on the subject cited above. In this connection, it is to inform you that the guest house was inspected by the officer concerned from this department on 19.03.2024 in the presence of Mr. Antaryami (Manager) and it was observed that building is comprised of Ground + 04 upper floors. During inspection, following shortcomings were observed:

1. First Aid Hose reels found non functional.
2. Fire pump not in auto start mode.
3. Exit signages are not adequately provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

The applicant is requested to rectify the shortcomings at the earliest for further action.

Yours faithfully,


(Atul Garg)

Director of
Delhi Fire Service
Tel: 011-23414000

Copy to:-

The Licensee,
New Royal Guest House at 1643, SPM Marg, Delhi - 110006.

21/3
21/3