



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/3
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2024/ 142

Dated: 28/03/2024

To,

The Manager,
ST. Paul East Delhi Public School,
D - 593, West Vinod Nagar, Delhi - 110092.

Sub: - Regarding grant of Fire Safety Certificate in r/o ST. Paul East Delhi Public School, located at D-593, West Vinod Nagar, Delhi – 110092.

Sir,


This has a reference to your Outdoor Diary No. 13599 dated 27.02.2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 15/03/2024 in the presence of Mr. Ranveer Singh Rathi (Manager) and observed that building comprised of Ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. Fire Extinguishers not provided.
2. First-Aid-Hose Reels provided but not functionable.
3. Fire pump provided but not functionable.
4. Overhead tank of 5,000 liters capacity is provided against the requirement of 10,000 liters.
5. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Manager, ST. Paul East Delhi Public School, located at D-593, West Vinod Nagar, Delhi-110092.
2. The Director of Education, Municipal Corporation of Delhi, 419, Udyog Sadan, Patparganj Industrial Area, Delhi-110092.