

c15

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2024/CC/55

DATED: 27/03/2024

To,

The Executive Engineer (Building).
Nigam Bhawan, Anand Parbat,
D.B Gupta Road, Karol Bagh,
New Delhi - 110005.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Coaching center Located at Plot No. 2/9, West Patel Nagar,, New Delhi - 110008.

Sir,

Please refer to letter No D/EE(B)/KBZ/2024/77 dated 12/02/2024 on the subject cited above. In this connection it is to inform you that the above said building has been inspected by the officers concerned of this department on 19/03/2024 in presence of Mr. Chander Tripathi from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. All the class rooms where number of students are more than 45 two exit doors of 1m width are required to be provided.
2. One staircases of width 150 cm found provided against required 02 staircase of 1.5 m clear width.
3. Fire Check Doors found not provided in basement.
4. Smoke management system in basement found not provided.
5. Hose reel system found nonfunctional.
6. Automatic sprinkler system found not provided in basement.
7. The main pump of 2280lpm & stand by diesel driven pump of similar capacity and jockey pump of 180lpm at ground level found not provided.
8. Underground tank of 150000 ltr capacity was not seen during the inspection.
9. Exit signage found not provided at some places.
10. Communication system found not provided in lift car.
11. As building plans of all floors has not been submitted.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation with this department for further consideration in the matter.

Copy to:-


(Atul Garg)
(Director)
Delhi Fire Service
28/3/24

1. The, Owner/ Occupier Coaching center Located at Plot No. 2/9, West Patel Nagar,, New Delhi - 110008.