

c/29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2024/ School | 125

Dated: -22/03/2024

To,

The Principal,  
Royal Indian Public School,  
D-55 A, Sita Puri-I, Street No. 17,  
Dabri Palam Road, New Delhi-110045.

**Subject: Renewal of Fire Safety Certificate in r/o Royal Indian Public School, Located at D-55 A, Sita Puri-I, Street No. 17, Dabri Palam Road, New Delhi-110045.**

Sir,

Please refer to your email dated 15/02/2024 on the subject mentioned above. In this connection it is to inform you that the premises was re-inspected by the officer concerned of this department on 18/03/2024 in the presence of Ms. Shikha (IT) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. The school activities were noticed at 3<sup>rd</sup> floor. Therefore two stairs of 1.5 m clear width found not provided for 3<sup>rd</sup> floor.
2. Terrace pump of 450 lpm capacity found nonfunctional on auto mode.
3. Exit signage found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

  
(Anil Garg)  
Director  
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi - 110054