

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2024/SZ/ 156
To

Dated: 28/03.../2024

Mr. Om Prakash Singh (DGM) NCC,
School Building at Redevelopment of Nauroji Nagar,
New, Delhi

Sub: Regarding issuance of Fire Safety Certificate in r/o School Building at Redevelopment of Nauroji Nagar, New, Delhi.

Sir,

This has reference to your Email dated 05/03/2024 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.03.2024 in the presence of Mr. Om Prakash Singh (DGM) NCC to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The 06 mtr internal road width is not provided.
2. Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE