

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/EH/2024/SZ/119
To

Dated: 26/3/2024

The Addl. Commissioner of Police,
Lic Branch 1st Floor PS Defence Colony,
New Delhi- 110049

Sub: Regarding issuance of FSC in r/o M/s Staple (A Unit of Scram) located at Plot No 82,
3rd Floor, GK-2, New Delhi 110048

Sir,

This has reference to your **MHA Portal ID 2024022602182 dated 26/02/2024 & MHA Portal ID 2024022802280 dated 29/02/2024** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.03.2024 in the presence of Mr. Sangram Singh to verify the fire safety measures installed in the building and observed that the restaurant is running 3rd Floor of the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Electric Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM not provided.
2. Underground tank capacity 1, 00,000 ltrs not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

