

01/18



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No: F.6/DFS/MS/WZ/Coaching Centre/2024/ 57

Dated: - 01/10/2024

To

The Authorized Signatory,  
FIIT JEE Coaching Center,  
Property No. 15/35, Punjabi Bagh,  
New Delhi - 110026.

Sub.: Regarding issuance of Fire Safety Certificate in r/o FIIT JEE Coaching Center, property No. 19/35, Punjabi Bagh, New Delhi - 110026.

Sir,

Please refer to your letter no. Nil, received through Outdoor Diary No.- 8805 dated 17/11/2023, on the subject cited above. In this connection, it is to inform you that the building/premises have been inspected by the officer concerned of this department on 26/12/2023 in the presence of Sh. Ajay Kumar to check the provisioning of fire safety arrangements provided in the building.

During inspection, it has been observed that the building is comprised of Basement + ground + three upper floors. Fire safety arrangements such as fire extinguishers, first -Aid hose reel, pumping arrangements, water storage tank etc. have been provided in the building. However, the following shortcomings were observed.

1. Two staircases of width 1.50 mts & 1.20 mts are provided against requirement of 02 stairs of 1.5 mts each.
2. One door of width 1 x 1mtr is provided in classroom having students more than 45 against requirement of 2 x 1.2mtr.
3. Fire Check Door is not provided in basement.
4. First- Aid Hose reel is provided but not functional.
5. Automatic Sprinkler System is not provided in basement.
6. Main Fire Pump of capacity 450 lpm is provided but not functional.
7. Over Head water storage tank capacity of 10,000 ltrs is provided but found empty.
8. Exit Signages are not provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

  
(Anil Garg)  
Director

dc  
28/3/2024