

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/Club/2024/SZ/157
To

Dated 28/03/2024

The Addl. Commissioner, (Lic/Branch)
1st Floor, P.S. Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Safdarjung Club, at Safdarjung Enclave, New Delhi 110029.

Sir,

This has reference to with **MHA Portal ID 2024013000999 dated 06/03/2024** on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.03.2024 in the presence of Mr. Pardeep Verma to verify the fire safety measures installed in the building. During inspection, following points were observed:

- 1 The Fire check door closing Device found removed.
- 2 Smoke management system found not functional.
- 3 Automatic Sprinkler system provided but non functional.
- 4 Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

of/ln