

c/79

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/129

Dated: 28/03/2024

To

The Joint Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

Subject: - Renewal of Fire Safety Certificate in respect of M/s Sagar Palace Guest House, Located at 47/16, Old Rajinder Nagar, Bara Bazar Marg, New Delhi-110060.

Sir,

Please refer to online application No. 2024021801805, dated 14/03/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 23/03/2024 in the presence of Sh. V.N Thakur (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. MOEFA and PA system found nonfunctional.
2. Pumps at terrace level found nonfunctional in auto mode.
3. Coaching centre was found running in basement.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.


(Atal Garg)
Director
Delhi Fire Service
dc
26/3/24

Copy to: - The Manager, M/s Sagar Palace Guest House, Located at 47/16, Old Rajinder Nagar, Bara Bazar Marg, New Delhi-110060.