

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/School/2024/ 156

Dated: 03/04/2024

To

School In charge /HOS,  
Govt. Sarvodaya Kanya Vidyalaya School,  
Mata Sundari Road, 23, Deen Dayal Upadhyay Marg,  
New Delhi.

**Sub: Regarding issuance of FSC in r/o Govt. Sarvodaya Kanya Vidyalaya School located at Mata Sundari Road, 23, Deen Dayal Upadhyay Marg, New Delhi.**

Sir,

This has reference to your letter no. nil dated 23/02/24, on the subject cited above. In this regard, it is to inform you that the site was visited by officers concerned of this department on 22.03.2024 in the presence of **Dr. Prerna Sharma (Principal)** and following shortcomings are observed.

1. Hose reel is not provided.
2. Overhead tank of 10,000 liter is not provided.
3. Fire Pump of 450 LPM capacity is not provided.

In view of above, fire safety certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter. Running school without valid Fire Safety Certificate is at the risk and liability of school management, concerned authority may take action at their end.

Yours faithfully,

  
(Atul Garg)  
**DIRECTOR**  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.