

c-58

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2024/EH/124  
To,

Dated: 02/04/2024

Sh. Randhir Kumar Arora,  
House No.11 B, Citizen Enclave,  
Sector-14, Rohini,  
Delhi-110085.

**Sub:** Issue of FSC in r/o M/s Spicy Affair Restaurant (Sanvi agencies Pvt Ltd) at Shop No.115 to 119, First Floor, W Mall Pearls, Corporate, Manglam Palace, Sec-3, Rohini, Delhi-110085.


Sir,

Kindly reference to online application No. 2024030102432 dated 02.03.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **18.03.2024** in presence of **Sh. Randhir Kumar Arora**, to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Additional inward opening doors on exiting exit doors found installed.
2. Detector system provided but found not functional.
3. Manually operated electric fire alarm system provided but not functional.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/)  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

  
(Atul Garg)  
DIRECTOR

Ph; 011-23414000

1. Copy to: MHA Id- 2024030102432 dated 02.03.2024.
- OR  
Mg