

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/Misc/NDZ/2024 / 161

Dated: 02/04/2024

To

The Assistant Engineer (E),  
(Delhi High Court & ND/ Central),  
MSO Building, Ground Floor, New Delhi -110002.

**Sub:- Regarding inspection of existing arrangement of fire fighting system vis underground tank, boosting arrangement etc. constructed under the project redevelopment of Chandni Chowk Road in accordance with the 61st meeting of nodal officers/ Principal Secretary (PWD) regarding orders/ Direction of Hon'ble High Court in W.P.(C) No. 7885/2020 titled as "Court on its own motion vs SRDC & Ors".**

Sir,

This is in reference to your letter outdoor diary no.12878 dated 08.02.2024 on the subject cited above. In this regard, it is to inform you that the site was visited by the team of officers concerned of this department on dated 20.03.2024 in the presence of Mr. Sabir Ali (A.E.) & Mr. Manish (J.E.). During inspection following shortcomings were observed:

1. Required water pressure in hydrant system at the remotest point not found.
2. Replenishment arrangements of underground water tank not provided.
3. Fire hydrant couplings are missing at some places.
4. Calculation sheet for fire fighting system should be provided.
5. Drawing and plan of whole fire fighting system arrangements should be provided.

Hence, you are requested to inform this department whenever your site is ready for inspection. Only after your intimation in this regard, this department will conduct the re-inspection and provide the status as required.

Yours faithfully,

  
(Anil Garg)  
Director  
Delhi Fire Service  
Tel: 011-23414000  
o/c  
21/3

**Copy to:-**

1. The Chief Engineer, PWD, MSO Building, ITO, New Delhi.
2. The Executive Engineer (E), (Delhi High Court & ND/ Central), MSO Building, Ground Floor, New Delhi -110002.