

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/CGHS/SZ/2024/ 170

DATED: 04/04/2024

To,

The President,
Pacific CGHS Ltd.
Plot No-39, Sector-10, Dwarka,
New Delhi-110075.

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o Pacific CGHS Ltd. Located at Plot No-39, Sector-10, Dwarka, New Delhi -110075.

Sir,

Please refer to your letter No. nil dated 14/03/2024 on the subject cited above. In this connection it is to inform to you that the above said premises was re-inspected by the officer concerned of this department on 26/03/2024 in the presence of Sh. R.K Sharma (Secretary) from fire safety point of view.

During the course of inspection followings shortcoming are observed:-

1. Six meter wide internal road around the building found encroached.
2. Only one fire extinguishers of ABC type 5Kg capacity is found provided against required two fire Extinguishers at some floors.
3. Hoses and branches found missing at some floor.
4. PA system found nonfunctional.
5. Exit signage found removed at some places.
6. Communication system in lift car found removed.
7. Dully fill form J & K are not submitted.
8. During the visit one hose reel was operated multiple leakage were noticed from hose reel/ nozzle / valve. All the branches, nozzles, hose fittings & hoses must IS marked.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.