

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Indl./2024/SZ/ 162  
To

Dated: 02/04/2024

The Executive Engineer (Bldg) HQ,  
Municipal Corporation of Delhi,  
9<sup>th</sup> floor, Civic Center, Minto Road,  
New Delhi 110002.

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No. 27, Known as 227,  
Okhla Industrial Area, Phase-II, New Delhi 110020

Sir,

This has reference with **online ID 10095649 dated 19/03/2024** on the subject cited above. In this connection, it is to inform you that the premise has been inspected by officers concerned of this department on 28.03.2024 along with Mr. Amit Kumar Sharma JE (Bldg) MCD & Mr. Mahesh Kumar AE (Bldg) MCD to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. Fire check doors not provided in the building.
2. Smoke management system not provided in the basement.
3. First aid hose reel provided but found nonfunctional.
4. Automatic sprinkler system head not installed.
5. Electrical Fire Pump capacity 2280 LPM, Diesel Engine Pump 2280 LPM and Jockey Pump 180 LPM not provided.
6. Underground tank capacity 2, 00,000 ltrs not provided.
7. Exit signage not provided.
8. Lift is not installed.
9. Standby power supply not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

or m