



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/Ind./2024/SZ/ 169  
To

Dated: 03/04/2024

The Authorized Signatory,  
Exhibitions India Pvt LTD,  
Plot No C- 103, Okhla Industrial Estate  
Phase-III, New Delhi 110020

Sub: Regarding issuance of Fire Safety Certificate in r/o Plot No C- 103, Okhla Industrial Estate Phase-III, New Delhi 110020

Sir,

This has reference with letter received through Outdoor diary no 11839 dated 12/01/202 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28.03.2024 in the presence of Mr. Suneet Katharina (CFO) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Smoke ventilation system provided but found not functional.
2. First aid hose reel provided but found nonfunctional.
3. Automatic sprinkler system provided but found nonfunctional.
4. Internal hydrant provided but found nonfunctional.
5. Fire Pumps are not on auto mode.
6. Temporary structure at terrace level is not allowed.

The same observations has already been issued and communicated earlier by this department vide letter of even no 4431 dated 13/12/2023.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE