

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/Hospital/SZ/2024/ 164

Dated: 02/04/2024

To,

The Director,
Rosewood Hospital (A unit of J.L.K.D Healthcare Pvt. Ltd.),
5, J-L Block, Roshan Garden, Najafgarh, New Delhi- 110043.

Sub: - Regarding renewal of fire safety certificate in r/o Rosewood Hospital (A unit of J.L.K.D Healthcare Pvt. Ltd.), located at 5, J-L Block, Roshan Garden, Najafgarh, New Delhi-110043.

Sir,

This has reference to your online email Id rosewoodhospital@gmail.com dated 29.02.2024, on the subject cited above. In this connection, it is to inform you that the Above said hospital building was inspected by the officers concerned of this department from safety point of view on 15.03.2024 in presence of Dr. Panday (SMO), and found that the FSC of the hospital building was issued by this department vide letter No. F.6/DFS/MS/2021/Hospital/148 dated 01.02.2024 for lower ground, ground plus two upper floors. But now the hospital management constructed one more floor (third floor).

During the course of inspection, the following shortcomings have been observed: -

- 1 Hose reels system found provided but not functional.
- 2 Internal hydrant system found provided but not functional.
- 3 Fire pumps found provided but not functional in auto mode.
- 4 Exit Signage found not provided.
- 5 Constructed one more floor, this is the case of additional alteration, advised to submit sanctioned/as built building plan through concern licensing/building sanctioning authority.

Keeping in view of above, renewal of fire safety certificate cannot be considered at this stage. You are hereby directed to rectify the above said shortcomings under intimation to this department for taking further necessary action in this matter.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Director of Health Service, Govt. of NCT of Delhi, School Block Shakarpur, New Delhi-110092.