



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001**

No. F6/DFS/MS/EH/WZ/2024/ 171

Dated: 04/10/2024

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

**Sub: - Issuance of Fire Safety Certificate in respect of M/s The Yellow Chilli, (A unit of NKCR Ventures Pvt. Ltd.) located at Property No. Z 10, Right Side, First Floor, Rajouri Garden, New Delhi-110027.**

Sir,

Please refer to the online application Id No. 2024030702736 dated 08/03/2024 & 2024031302937 dated 13/03/2024 received through MHA portal on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 01/04/2024 in the presence of Sh. Ajay (Manager) to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said restaurant is running at 1<sup>st</sup> floor in a building comprised of basement, stilt, upper ground + 03 upper floors. The fire safety arrangements such as Fire Extinguishers, First-Aid Reels, MOEFA, etc are provided. However the following shortcomings were observed.

1. First-Aid Hose Reel & Internal Hydrant is provided but not functional.
2. Terrace level pump capacity of 450LPM is not provided.
3. Overhead water storage tank capacity of 20000ltrs is not provided.
4. Exit Signage's are not provided.

In view of above Shortcomings, the application for issuance of fire safety certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully,

  
(Arul Garg)  
Director

Copy to: -

1. The Owner/Occupier M/s. The Yellow Chilli, (A unit of NKCR Ventures Pvt. Ltd.) located at Property No. Z 10, Right Side, First Floor, Rajouri Garden, New Delhi-110027.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id:- ([dhowest\\_zone@gmail.com](mailto:dhowest_zone@gmail.com))