

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2024/SZ/ 141
To

Dated: 05..10.1./2024

The Joint Commissioner of Police,
Lic-Branch, 1st Floor, P.S Defence Colony,
New Delhi 110049

Sub: Regarding issuance of Fire Safety Certificate r/o M/s Bloom Hotel (A Unit of Imperativ Hospitality Pvt Ltd, located at A-3, Chittranjan Park, New Delhi-110019.

Sir,

This is in reference with **MHA Portal ID 2024030402551 dated 04-03-2024** on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02/04/2024 in the presence of Mr. Keshav to verify the fire safety arrangements installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Check Door not provided as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided as per clause 7.31 of UBBL 2016.
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
4. Exit Signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

[Handwritten signature]