

c-11

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

NO. F6/DFS/MS/SZ/2024/cc/59

DATED: 05/04/2024

To,

The Executive Engineer (Building).
Nigam Bhawan, Anand Parbat,
D.B Gupta Road, Karol Bagh,
New Delhi - 110005

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Coaching center Located at Plot No. 49, Sector-12B, Dwarka, New Delhi - 110075.

Sir,

Please refer to letter No DFS Outdoor diary No. 13143, dated 21/03/2024 on the subject cited above. In this connection it is to inform you that the above said building has been inspected by the officers concerned of this department on 27/03/2024 in presence of Mr. Naurang Singh from fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Two staircases of 143 cm & 150 cm widths found provided against required 02 staircase of 1.5 m clear width for upper floors.
2. Two class Room Doors of 1m clear width are required to be provided for each class room having more than 45 students.
3. The Passage/ corridor of 1.5 m clear width to staircases found not provided.
4. Fire Check Door is not provided in basement floor.
5. Terrace pump of 450 lpm capacity found provided against required 900 lpm capacity.
6. Overhead fire water tank of 2500 ltr capacity found provided against required water tank of 15000 ltr exclusively for fire fighting.
7. Exit Signage found not provided at some places.

In view of the above shortcomings issuance of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are requested to comply the above mentioned shortcomings under intimation to this department for further consideration in the matter.



(Atul Garg)
(Director)

Delhi Fire Service
OK
5/4/24

Copy to:-

1. The Owner/ Occupier Coaching center Plot No. 49, Sector-12B, Dwarka, New Delhi - 110075.