



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c. 485  
7/11  
आपदाभीम  
अमृत महोत्सव

No. F6/DFS/MS/Hotel/SZ/2024/ 14

Dated: 08/04/2024

To,

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Hotel The Suryaa, New Friends Colony, New Delhi-25.**

Sir,

With reference to the MHA portal online application no. 2024031903222/ 2023082315045/ 2023090515656/ 2024022802310 on the subject cited above, it is informed that the said building was inspected by a team of officers concerned of this department on 30.03.2024 in the presence of Sh. Juyul Singh, Manager (Corporate Affairs) & Sh. Mukesh Sharma, Director (Engineering) and following shortcomings were observed:

1. Smoke Management System in the basement is inadequate and the available system was found nonfunctional.
2. There is no proper segregation of lift lobby in the basements & upper floors.
3. Lift sinages and exit sinages were found inadequate and were not as per standards.
4. Electrical panels in common areas/means of egress may be relocated or may be protected with modular system.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)  
Director

Delhi Fire Service

**Copy to:-**

1. The Executive Engineer (Building), MCD, Jal Vihar, Lajpat Nagar, New Delhi-24.
2. The Owner/Occupier, M/s Hotel The Suryaa, New Friends Colony, New Delhi-25.