



No. F6/DFS/MS/BNQT/NDZ/2024/55

Dated: 04/04/2024

To,

The Manager,  
M/s L' Elegant The Royal Banquet  
Plot no. 1/A, Star City Mall,  
Mayur Vihar - 1, Delhi - 110092.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s L' Elegant The Royal Banquet located at Plot no. 1/A, Star City Mall, Mayur Vihar - 1, Delhi - 110092.**

Sir,

This has a reference to your MHA Portal application No. 2024030102387 dated 08/03/2024, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 22/03/2024 in the presence of Mr. Satish Kapoor (Owner) and observed that building comprised of basement, ground plus two upper floors only.

**Following shortcomings were observed during time of inspection:**

1. Fire check doors not provided.
2. First-Aid-Hose Reels provided but not functional.
3. MOEFA is not provided but not functional.
4. Exit Signage's not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. Mr. Satish Kapoor, M/s L' Elegant The Royal Banquet located at Plot no. 1/A, Star City Mall, Mayur Vihar - 1, Delhi - 110092.
2. The Joint Commissioner of police (Lic), 1<sup>st</sup> Floor, P. S. Defence Colony, New Delhi-110024.  
w.e.f.-MHA portal ID - 2024030102387 Dated- 08/03/2024.