



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

①



No: F.6/DFS/MS/2024/WZI 159

Dated: 05/04/2024

To,

The Executive Engineer (Elect.),
Keshavpuram Zone, 2nd Floor,
MCD Community Centre,
Ashok Vihar, Phase-2, Delhi-110052.

Sub: - Regarding issuance of Fire Safety Certificate in r/o MC Primary School located at C-2,
Ashok Vihar, Phase-2, Delhi- 110052.

Sir,

This has reference to your e mail id dated 06/03/2024 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 01.04.2024 to see the compliance of the requisite fire safety measures. Sh. Dinesh Kumar was present at the time of inspection.

During the course of inspection it was observed that the building comprised of Ground plus two upper floors. Your request for issuance of FSC is rejected as the following shortcomings were observed:


1. Gate width found 3.70 m against the required width of 4.5 m.
2. Width of staircase found 1.40 m & 1.20 m against the required width of 1.50 m each.
3. There is only 01 continuous staircase up to terrace against the requirement of both staircases up to terrace.
4. Pumping system found installed but could not be tested due to non availability of power supply.
5. Exit signage's not provided.
6. Electrical panel found installed under the staircase which has to be removed to a safer place.
7. Building plan and elevation plan not provided.

Keeping in view of above shortcomings Fire Safety Certificate is not considered at this stage and rejected. You are advised to rectify the above-mentioned shortcomings for further consideration in this matter.

Yours Faithfully


(Atul Gang)
Director

Ph. 011-23414000


3/198

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.