



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 175

Dated: 08/04/2024

To

Sh. Narender Kumar Gaur (Fire Officer),
New Delhi Municipal Council,
Mezzanine Floor, Sansad Marg,
Palika Kendra, New Delhi-110001

Sub: Regarding renewal of Fire Safety Certificate in r/o Atal Adarsh Vidyalaya Sr. Sec. School, East Kidwai Nagar, New Delhi-110023 (School ID: 2026073)

Sir,

This has reference to the email received from fo@ndmc.gov.in dated 22/03/2024, on the subject cited above. In this connection, the school premises was visited by the officer concerned of this department on 23/03/2024 in the presence of Sh. Narender Kumar Gaur (Fire Officer), NDMC to verify the status of the fire safety arrangements provided therein. During the inspection, the shortcomings observed are as below.

1. Hose-reel found provided but non-functional.
2. MOEFA/MCPs found provided but non-functional.
3. Yard hydrant hose-box provided near school found empty/without branch & hoses.
4. The terrace level pump was not on auto mode.
5. The exit signage found removed at some places.
6. Lift signage found removed.

In view of the above, the application for renewal of fire safety certificate is rejected. You are advised to rectify the above shortcomings under intimation to this department for further action in the matter.

Yours faithfully,


(Aful Garg)
Director
Delhi Fire Service
01/04/24

Copy to: -

1. Principal, Atal Adarsh Vidyalaya Sr. Sec. School, East Kidwai Nagar, New Delhi-110023