

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/BP/2024/ 176

Dated: 08/06/2024

To,

Dr. Nitin Kumar, Medical Superintendent-Nursing Home,  
Nursing Home Cell, Govt. of NCT, 3<sup>rd</sup> floor,  
S-1, School Block, Shakarpur, Delhi-110092.

Sub: - Clearance from Fire Safety Point of view in r/o Devputra Hospital, Kh. No. 24/7,  
24/17, 24/15 Bishal Garden, Ranhola, Nangloi, Delhi - 110041

Sir,

Please refer your letter request No.-F.24/New/West/DGHS/NHC/2024-27/426 dated 22.02.2024, on the subject cited above. In this connection, it is to inform you that the building plans are scrutinized from fire & life safety point of view and observed that there is a proposal of construction of Devputra Hospital, Kh. No. 24/7, 24/17, 24/15, Bishal Garden, Ranhola, Nangloi, Delhi - 110041. Following shortcomings are observed:

1. Alternate exit in patient rooms is not proposed as per NBC -part 4, 2016.
2. No of Beds are not mentioned in OT at 4<sup>th</sup> floor.
3. Travel distance to an exit from the dead end of the corridor is more than 6 meter which contravenes the clause 7.8.2 of UBBL- 2016.
4. Hight of the building is not clear on section/elevation plan.
5. Smoke management of each floor plan are not proposed.

Accordingly, the case is hereby rejected.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Ph. 011-23414000

