

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/WZ/2024/ 172

Dated: - 05/04/2024

To.

Dr. Sunil Sumbi. Medical Superintendent, Sri Balaji Action Medical Institute, A-4, Paschim Vihar, New Delhi-110063.

Subj:- Regarding renewal of Fire Safety Certificate in respect of Sri Balaji Action Medical Institute (Unit of Lala Munni Lal Mange Ram Charitable Trust) located at FC-34, A-4, Paschim Vihar, New Delhi-110063.

Sir,

This is in reference to your letter no. SBAMI:MS:2024:2416 dated 02/02/2024 on the subject cited above. In this connection it is to inform you that the aforesaid buildings have been inspected by the officers concerned of this department on 27/03/2024 in presence of Sh. Mandeep Lakra (Manager, Maintenance). During the course of inspection it has been observed that the hospital building is comprised of basements, ground plus four upper floors. Fire safety arrangements such as fire extinguishers, first aid hose reel, two main electric pump having capacity 2850 LPM each, one D.G. pump capacity 2850 LPM, two jockey pumps capacity 180 LPM each, underground water tank having capacity 2,00,000 ltrs, overhead water tank capacity 30,000 ltrs etc. found provided. However, following shortcomings were observed: -

1. The internal road of hospital found encroached due to ongoing civil work.

2. Ventilation system found removed due to renovation work of floors in west-side-wing of building. Either mechanical ventilation system or openable window shall be provided.

In view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faith

Copy to:-

1. The Executive Engineer (Bldg.), Municipal Corporation of Delhi, 9th Floor, Civic Centre, Minto Road, New Delhi-110002.