

C-84

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001

No.F6/DFS/MS/SZ/2024/137

Dated: 04/04/2024

To

The Joint Commissioner of Police,
Licensing Unit 1st Floor,
P.S Defence Colony,
New Delhi-110049

**Subject: - Renewal of Fire Safety Certificate in respect of The Sun Court Hotel,
Located at 8A/33, WEA, Karol Bagh, New Delhi-110005.**

Sir,

Please refer to online application No. 2024031603080, dated 20/03/2024 on the subject mentioned above. In this connection it is to inform you that the inspection of the premises was carried out by the officer concerned from this department on 30/03/2024 in the presence of Sh. Anchit (Manager) from fire safety point of view.

During the course of inspection following shortcomings are observed:

1. Fire Check Doors found not provided.
2. Smoke management system found not interlinked with MOEFA.
3. Pumps at terrace level found nonfunctional on auto mode.
4. Communication system in lift car found removed.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered. The applicant is directed to comply the shortcomings under intimation to this department for further consideration in the matter.


(Atul Gang)
Director
Delhi Fire Service

Copy to: - The Manager, The Sun Court Hotel, Located at 8A/33, WEA, Karol Bagh, New Delhi-110005.