

c/193

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI - 110001**

No.F6/DFS/MS/SZ/2024/ 188

Dated: 12/04/2024

To,

The President,  
The Gold Croft CGHS  
Plot No. 4, Sector - 11 Dwarka.

**Subject: - Renewal of fire safety certificate in r/o The Gold Croft CGHS Located at Plot No. 4, Sector - 11 Dwarka New Delhi.**

Sir,

Please refer to your letter No- Gold/4040/2024 dated -20/02/2024 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer concerned of this department on 02/04/2024 in the presence of Sh. Udai vir Singh (Manager) from fire safety point of view.

**During the course of inspection following shortcomings are observed**

1. Six meter wide internal road around the building found encroached.
2. Width of Staircase must not be less than 1.25m.
3. Fire Check door Found removed at some places.
4. Only one ABC type 5kg capacity fire extinguisher was found provided against required two fire extinguishers at each floor.
5. MOEFA found nonfunctional.
6. Exit Signage Found removed at some places.

In view of the above shortcomings renewal of Fire Safety Certificate from fire safety point of view cannot be considered at this stage. You are directed to comply the shortcomings under intimation to this department for further consideration in the matter.

Yours faithfully,

(Atul Garg)  
Director,  
Delhi Fire Service.

o/c

Copy to:-

The Joint Director (Building) DDA, Vikas Sadan, INA, Delhi-110023.