

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/EH/2024/SZ/130

Dated: 12/04/2024

To

The Joint commissioner of Police,  
Lic Unit, 1<sup>st</sup> Floor PS Defence Colony,  
New Delhi 110049

Sub: - Regarding issuance of Fire Safety Certificate in r/o M/s PRET A Manager (A Unit of Reliance Brands Ltd, located at Unit No G6F, Ground Floor, CPD 26 R, Eldeco Centre, MRTS Station Integrated Plot at Malviya Nagar Metro Station situated at Malviya Nagar, New Delhi 110017

Sir,

This has reference to with **MHA Portal ID 2024031202874** dated **12/03/2024** on the subject above. In this connection, it is to inform you that the inspection of the premise was conducted by the officers from Delhi Fire Service on 08/04/2024 in the presence of Mr. Deepak Kumar to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. There are two doors having width of 2 mtr & 0.70 mtr against the required width of 1.50 mtr each as per UBBL 2016.
2. Electrical Penal found installed in the escape routes near staircases, which is not acceptable.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

delhi fire service